



Government Of West Bengal
Office Of The Divisional Fire Officer,Purulia
West Bengal Fire & Emergency Services
Purulia Fire Station, Ranchi Road,Purulia, Pin:- 723101

Memo no.:FSR/0125186211600007

Date: 26-06-2023

From:
Divisional Fire Officer,Purulia
West Bengal Fire & Emergency Services

To: GURUKUL TEACHERS' TRAINING INSTITUTE
AT PO. Jiudaru, RS. Plot no. 1799/1746, KH no. 34, Mouza -Jiudaru, P.S.- Kotshila, Sub-Division- Jhalda, Dist.-
Purulia, PIN-723213,

Sub: Sub: Fire Safety Certificate for the existing G+2 storied building under group educational, name & style as
"GURUKUL TEACHERS' TRAINING INSTITUTE" at, Premises/Holding no. Nil, Vill. & P.O Jiudaru, R.S Plot no.
1799/1746, Kh. no. 34, Mouza - Jiudaru, P.S Kotshila, Sub-Division - Jhalda, Dist. Purulia, Pin - 723213

This is in reference to your application no. 0125189231600021 dated 02-06-2023 regarding the Sub: Fire Safety Certificate for the existing G+2 storied building under group educational, name & style as "GURUKUL TEACHERS' TRAINING INSTITUTE" at, Premises/Holding no. Nil, Vill. & P.O Jiudaru, R.S Plot no. 1799/1746, Kh. no. 34, Mouza - Jiudaru, P.S Kotshila, Sub-Division - Jhalda, Dist. Purulia, Pin - 723213

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

Construction:

1. The whole construction of the proposed building shall be carried out as per approved plan drawings conformed the relevant building rules of local Body.
2. The floor area exceeds 750m² shall be suitably compartmented by separation walls up to ceiling level having at least two hours Fire resisting capacity.

Open Space & Approach:

3. The open space surrounding the building shall conform the relevant building rules as well as permits the accessibility and manoeuvrability of Fire appliance with turning facility.
4. The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting up to 20 M.T.
5. The width and height of the access gates into the premises shall not be less than 4.5 – 5 M respecting abutting the road.

Staircase:

6. Both the stair case shall be extended up to roof level negotiating to the entire floor and shall be made that they are accessible in at least two different directions from every point in any open area, or from any door.

7. Two nos. additional R.C.C stair case of same size (2 meter width) shall be constructing at the dead ends, as marked in the plan drawing, for cover the Dead ends.

Fire Fighting Water:

8. Overhead reservoir of 10,000 litres. Capacity exclusively for Fire fighting purpose with replenishing arrangements @ 1000 lts./min. Preferably from two different sources of water supply shall be provided. The water reservoir shall have overflow arrangement with the domestic water reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.

Hose reel System:

9. Provision of standard Hose Reel Hose supplied from the overhead reservoir through Booster Pump, 10HP capacity, @ 2 (Two) Number on each floor as remote as practicable from each other /at the both stair case, through 100 mm Class-C MS pipe lines shall have to be made in all the floor of the building satisfy the code of I.S. 3844-1989.

10. One number of 2 way Fire Service inlet shall be provided at 0.9 Meter of height on the ground floor duly connected with that Down Comer Column.

11. Alternative Power Supply shall be provided through Diesel Generator to run the Fire Pump and the Pump of the Deep Tube Well during normal power failure.

Electrical Installation & Distribution:

12. The electrical installation shall be adequately protected with M.C.B & CO2/D.C.P.

13. Manually operated Electrical Fire Alarm system with at least three numbers of break glass type call boxes fitted with Hooters along with public address system, talk back system at each floor connecting with audio-visual panel board shall be made in Control Room. The Control Room shall be located at the entrance of Ground Floor of the building, other requirements of the system shall be made conforming I.S. 2189 – 1988.

First Aid Fire Fighting System:

14. First Aid Fire fighting arrangement in the style of placing suitable type of portable Fire Extinguishers, at least 2 * 6 kg capacity ABC & 2*4.5KG Co2 type for every 600 sq. meter floor area or part thereof, with minimum 4 Extinguishers per floor & Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made as per latest specification.

General Recommendations:

15. The staffs shall be conversant with installed Fire Fighting equipment of the school building and to operate in the event of

Fire and Testing.

16. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.

17. Mock Fire practice and evacuation drill shall be performed periodically with participation of all students of building.

18. This shall be tested as provisional N.O.C. On compliance of all the above Fire and Life safety recommendations, the Director General, West Bengal Fire & Emergency Services shall be approached for necessary inspection and testing of the installation, Final N.O.C. in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

19. N.B.: Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this provisional N.O.C. will be treated as cancelled.

Signature valid

Digitally Signed.
Name: PLABAN MOHANTY
Date: 26-Jun-2022 10:22
Reason: Approved
Location: West Bengal

Memo No.: FSR/0125186211600007



GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER, PURULIA DIVISION
WEST BENGAL FIRE & EMERGENCY SERVICES
1ST FLOOR, PURULIA FIRE STATION, RANCHI ROAD, PURULIA-723101
Contact No.-03252-222002, Email Id.-purbnkdivn@gmail.com



Memo No. FES / PUR / 158 / 2024

Dated: 08 / 08 / 2024

Corrigendum

This is to certify that Fire Safety Certificate issued vide Memo no.- FSR/0125186211600007 dated- 26/06/2023 in favour of "GURUKUL TEACHERS' TRAINING INSTITUTE" at post-Jiudaru, R.S. Plot No.- 1799/1746, K.H. No.-34, Mouza - Jiudaru, P.S.- Kotshila, Sub-Division- Jhalda, Dist- Purulia, Pin-723213 is valid for 03 (Three) years from the date of issue of the certificate i.e. 26/06/2023.

W.B. 08/08/24.

Dy. Director, W.B.F.&E.S.
(Additional Charge of Divisional Fire Officer,
Purulia Division)
West Bengal Fire & Emg. Services.